

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	35.54	=	50.71	03 - MGD									99/99 - Continuous			
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD												99/99 - Continuous
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	1	--	Sample																	
					Permit Req.																	CL/OC - Chlorination/Occurances
					Value NODI																	
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	672.0	=	903.0	26 - lb/d												
					Permit Req.	<=	20850.0 MO AVG	<=	41700.0 WKLY AVG	26 - lb/d												02/DA - 2 Days Every Week
					Value NODI																	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

SANITARY DISTRICT OF DECATUR

User: keithrsdd
 Name: Keith Richard
 E-Mail: keithr@sddcleanwater.org
 Date/Time: 2023-02-09 09:28 (Time Zone: -06:00)

Report Last Signed By

User: TIMSDD89
 Name: Tim Gorden
 E-Mail: timg@sddcleanwater.org
 Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	002 External Outfall	Discharge:	002-0 EMERGENCY HIGH LEVEL OVERFLOW BYPASS
Facility:		Facility Location:	SANITARY DISTRICT OF DECATUR MAIN STP 501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
W0430350001

Principal Executive Officer			
First Name:	Kent	Title:	Executive Director
Last Name:	Newton	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample													
					Permit Req.													
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample													
					Permit Req.													
					Value NODI													
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample													
					Permit Req.													
					Value NODI													
74071	Flow	1 - Effluent Gross	0	--	Sample													
					Permit Req.													
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
No discharge during the month.

Attachments
No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR

User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:29 (Time Zone: -06:00)

Report Last Signed By

User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	003 External Outfall	Discharge:	003-0 TREATED CSO-OAKLAND AVENUE
Facility:	SANITARY DISTRICT OF DECATUR MAIN STP		
Facility Location:	501 DIPPER LANE DECATUR, IL 62522		

Report Dates & Status			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
W1150150004 ; RECEIVING WATER: SANGAMON RIVERNUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Kent	Title:	Executive Director
Last Name:	Newton	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	83.0				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.							Req Mon DAILY MX			19 - mg/L	DL/DS - Daily When Discharging			GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.42				12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.							Req Mon MINIMUM			12 - SU	DL/DS - Daily When Discharging			GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	136.0			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample						=	2.24			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	2.79			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon MO AVG			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	0.87	80 - Mgal/mo							DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.			Req Mon MO TOTAL	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Two days of discharge.

Attachments
No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR

User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:31 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	004 External Outfall	Discharge:	004-0 TREATED CSO-LINCOLN PARK
Facility:	SANITARY DISTRICT OF DECATUR MAIN STP		
Facility Location:	501 DIPPER LANE DECATUR, IL 62522		

Report Dates & Status			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
W1150150004 ; RECEIVING WATER: SANGAMON RIVERNUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Kent	Title:	Executive Director
Last Name:	Newton	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample												19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.											Req Mon DAILY MX			
					Value NODI											C - No Discharge			
00400	pH	1 - Effluent Gross	0	--	Sample											12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														Req Mon MINIMUM
					Value NODI														C - No Discharge
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														Req Mon DAILY MX
					Value NODI														C - No Discharge
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														Req Mon DAILY MX
					Value NODI														C - No Discharge
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.														Req Mon MO AVG
					Value NODI														C - No Discharge
82220	Flow, total	1 - Effluent Gross	0	--	Sample											80 - Mgal/mo	DL/DS - Daily When Discharging	CN - CONTIN	
					Permit Req.														Req Mon MO TOTAL
					Value NODI														C - No Discharge

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
No discharge during the month.

Attachments
No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR

User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:32 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	007 External Outfall	Discharge:	007-0 TREATED CSO-MCKINLEY AVENUE
Facility:	SANITARY DISTRICT OF DECATUR MAIN STP		
Facility Location:	501 DIPPER LANE DECATUR, IL 62522		

Report Dates & Status			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
W1150150004 ; RECEIVING WATER: SANGAMON RIVERNUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Kent	Title:	Executive Director
Last Name:	Newton	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	30.0				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.							Req Mon DAILY MX			19 - mg/L	DL/DS - Daily When Discharging			GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.14				12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.							Req Mon MINIMUM			12 - SU	DL/DS - Daily When Discharging			GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	208.0			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample						=	0.66			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	0.62			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon MO AVG			19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	3.75	80 - Mgal/mo							DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.			Req Mon MO TOTAL	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Two days of discharge.

Attachments
No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR

User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:33 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	008 External Outfall	Discharge:	008-0 TREATED CSO-SEVENTH WARD
Facility:	SANITARY DISTRICT OF DECATUR MAIN STP		
Facility Location:	501 DIPPER LANE DECATUR, IL 62522		

Report Dates & Status			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23
Status:	NetDMR Validated		

Considerations for Form Completion
W1150150004 ; RECEIVING WATER: SANGAMON RIVERNUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Kent	Title:	Executive Director
Last Name:	Newton	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	14.0				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L	DL/DS - Daily When Discharging			GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.15				12 - SU	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon MINIMUM			Req Mon MAXIMUM	12 - SU			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	42.0				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L	DL/DS - Daily When Discharging			GR - GRAB	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample						=	0.65				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX			19 - mg/L	DL/DS - Daily When Discharging			GR - GRAB	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	4.44				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon MO AVG			Req Mon DAILY MX	19 - mg/L			DL/DS - Daily When Discharging	GR - GRAB
					Value NODI															
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	0.52	80 - Mgal/mo							DL/DS - Daily When Discharging	CN - CONTIN			
					Permit Req.			Req Mon MO TOTAL	80 - Mgal/mo									DL/DS - Daily When Discharging	CN - CONTIN	
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
One day of discharge.

Attachments
No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR

User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:39 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
74062	Overflows	1 - Effluent Gross	0	--				Opt Mon MO TOTAL	4K - #/mo											
								C - No Discharge												

Permit
 Permit #: IL0028321 | Permittee: SANITARY DISTRICT OF DECATUR | Facility: SANITARY DISTRICT OF DECATUR MAIN STP
 Major: Yes | Permittee Address: 501 DIPPER LANE DECATUR, IL 62522 | Facility Location: 501 DIPPER LANE DECATUR, IL 62522
 Permitted Feature: A03 External Outfall | Discharge: A03-0 CSO-OAKLAND AVENUE CSO TREATMENT BYPASS

Report Dates & Status
 Monitoring Period: From 01/01/23 to 01/31/23 | DMR Due Date: 02/25/23 | Status: NetDMR Validated

Considerations for Form Completion
 W1370200010 ; RECEIVING WATER:BRIAR CREEK

Principal Executive Officer
 First Name: Kent | Title: Executive Director | Telephone: 217-422-6931
 Last Name: Newton

No Data Indicator (NODI)
 Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments
 No discharge during the month.

Attachments
 No attachments.

Report Last Saved By
 SANITARY DISTRICT OF DECATUR
 User: keithrsdd
 Name: Keith Richard
 E-Mail: keithr@sddcleanwater.org
 Date/Time: 2023-02-09 09:40 (Time Zone: -06:00)

Report Last Signed By
 User: TIMSDD89
 Name: Tim Gorden
 E-Mail: timg@sddcleanwater.org
 Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74062	Overflows	1 - Effluent Gross	0	--				Opt Mon MO TOTAL	4K - #/mo										
								C - No Discharge											

Permit
Permit #: IL0028321 | **Permittee:** SANITARY DISTRICT OF DECATUR | **Facility:** SANITARY DISTRICT OF DECATUR MAIN STP
Major: Yes | **Permittee Address:** 501 DIPPER LANE DECATUR, IL 62522 | **Facility Location:** 501 DIPPER LANE DECATUR, IL 62522
Permitted Feature: A04 External Outfall | **Discharge:** A04-0 CSO-LINCOLN PARK CSO TREATMENT BYPASS

Report Dates & Status
Monitoring Period: From 01/01/23 to 01/31/23 | **DMR Due Date:** 02/25/23 | **Status:** NetDMR Validated

Considerations for Form Completion
 W1370200010 ; RECEIVING WATER:BRIAR CREEK

Principal Executive Officer
First Name: Kent | **Title:** Executive Director | **Telephone:** 217-422-6931
Last Name: Newton

No Data Indicator (NODI)
Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments
 No discharge during the month.

Attachments
 No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR
User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:41 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit																				
Permit #: IL0028321		Permittee: SANITARY DISTRICT OF DECATUR				Facility: SANITARY DISTRICT OF DECATUR MAIN STP														
Major: Yes		Permittee Address: 501 DIPPER LANE DECATUR, IL 62522				Facility Location: 501 DIPPER LANE DECATUR, IL 62522														
Permitted Feature: A06 External Outfall		Discharge: A06-0 CSO-FAIRVIEW PARK CSO																		
Report Dates & Status																				
Monitoring Period: From 01/01/23 to 01/31/23				DMR Due Date: 02/25/23				Status: NetDMR Validated												
Considerations for Form Completion																				
W1370200010 ; RECEIVING WATER:BRIAR CREEK																				
Principal Executive Officer																				
First Name: Kent				Title: Executive Director				Telephone: 217-422-6931												
Last Name: Newton																				
No Data Indicator (NODI)																				
Form NODI: --																				
Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
74062	Overflows	1 - Effluent Gross	0	--	Sample															
					Permit Req.			Opt Mon MO TOTAL	4K - #/mo											
					Value NODI			C - No Discharge												
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
No discharge during the month.																				
Attachments																				
No attachments.																				
Report Last Saved By																				
SANITARY DISTRICT OF DECATUR																				
User: keithrsdd				Name: Keith Richard				E-Mail: keithr@sddcleanwater.org				Date/Time: 2023-02-09 09:41 (Time Zone: -06:00)								
Report Last Signed By																				
User: TIMSDD89				Name: Tim Gorden				E-Mail: timg@sddcleanwater.org				Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)								

DMR Copy of Record

Permit																				
Permit #: IL0028321		Permittee: SANITARY DISTRICT OF DECATUR						Facility: SANITARY DISTRICT OF DECATUR MAIN STP												
Major: Yes		Permittee Address: 501 DIPPER LANE DECATUR, IL 62522						Facility Location: 501 DIPPER LANE DECATUR, IL 62522												
Permitted Feature: A07 External Outfall		Discharge: A07-0 CSO-MCKINLEY AVE CSO TREATMENT BYPASS																		
Report Dates & Status																				
Monitoring Period: From 01/01/23 to 01/31/23				DMR Due Date: 02/25/23						Status: NetDMR Validated										
Considerations for Form Completion																				
W1370200010 ; RECEIVING WATER:BRIAR CREEK																				
Principal Executive Officer																				
First Name: Kent				Title: Executive Director						Telephone: 217-422-6931										
Last Name: Newton																				
No Data Indicator (NODI)																				
Form NODI: --																				
Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
74062	Overflows	1 - Effluent Gross	0	--	Sample															
					Permit Req.			Opt Mon MO TOTAL	4K - #/mo											
					Value NODI			C - No Discharge												
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
No discharge during the month.																				
Attachments																				
No attachments.																				
Report Last Saved By																				
SANITARY DISTRICT OF DECATUR																				
User: keithrsdd				Name: Keith Richard						E-Mail: keithr@sddcleanwater.org						Date/Time: 2023-02-09 09:42 (Time Zone: -06:00)				
Report Last Signed By																				
User: TIMSDD89				Name: Tim Gorden						E-Mail: timg@sddcleanwater.org						Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)				

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
74062	Overflows	1 - Effluent Gross	0	--				Opt Mon MO TOTAL	4K - #/mo											
								C - No Discharge												

Permit
Permit #: IL0028321 | **Permittee:** SANITARY DISTRICT OF DECATUR | **Facility:** SANITARY DISTRICT OF DECATUR MAIN STP
Major: Yes | **Permittee Address:** 501 DIPPER LANE, DECATUR, IL 62522 | **Facility Location:** 501 DIPPER LANE, DECATUR, IL 62522
Permitted Feature: A08 External Outfall | **Discharge:** A08-0 CSO-SEVENTH WARD CSO TREATMENT BYPASS

Report Dates & Status
Monitoring Period: From 01/01/23 to 01/31/23 | **DMR Due Date:** 02/25/23 | **Status:** NetDMR Validated

Considerations for Form Completion
 W1370200010 ; RECEIVING WATER:BRIAR CREEK

Principal Executive Officer
First Name: Kent | **Title:** Executive Director | **Telephone:** 217-422-6931
Last Name: Newton

No Data Indicator (NODI)
Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments
 No discharge during the month.

Attachments
 No attachments.

Report Last Saved By
SANITARY DISTRICT OF DECATUR
User: keithrsdd
Name: Keith Richard
E-Mail: keithr@sddcleanwater.org
Date/Time: 2023-02-09 09:42 (Time Zone: -06:00)

Report Last Signed By
User: TIMSDD89
Name: Tim Gorden
E-Mail: timg@sddcleanwater.org
Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:															
Permit #:	IL0028321	SANITARY DISTRICT OF DECATUR		SANITARY DISTRICT OF DECATUR MAIN STP															
Major:	Yes	Permittee Address: 501 DIPPER LANE DECATUR, IL 62522		Facility Location: 501 DIPPER LANE DECATUR, IL 62522															
Permitted Feature:	INF Influent Structure	Discharge: INF-G INFLUENT FLOW FROM GROUNDWATER DEWATERING SYSTEM																	
Report Dates & Status																			
Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23	Status:	NetDMR Validated														
Considerations for Form Completion																			
Principal Executive Officer																			
First Name:	Kent	Title:	Executive Director	Telephone:	217-422-6931														
Last Name:	Newton																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type						
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample Permit Req.	Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	
					Value NODI	Q - Not Quantifiable		Q - Not Quantifiable											
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Existing infrastructure does not allow for measurement of flow.																			
Attachments																			
No attachments.																			
Report Last Saved By																			
SANITARY DISTRICT OF DECATUR																			
User:	keithrsdd																		
Name:	Keith Richard																		
E-Mail:	keithr@sddcleanwater.org																		
Date/Time:	2023-02-09 09:43 (Time Zone: -06:00)																		
Report Last Signed By																			
User:	TIMSDD89																		
Name:	Tim Gorden																		
E-Mail:	timg@sddcleanwater.org																		
Date/Time:	2023-02-10 09:02 (Time Zone: -06:00)																		

DMR Copy of Record

Permit

Permit #:	IL0028321	Permittee:	SANITARY DISTRICT OF DECATUR	Facility:	SANITARY DISTRICT OF DECATUR MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522	Facility Location:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	INF Influent Structure	Discharge:	INF-L INFLUENT REPORTING		

Report Dates & Status

Monitoring Period:	From 01/01/23 to 01/31/23	DMR Due Date:	02/25/23	Status:	NetDMR Validated
---------------------------	---------------------------	----------------------	----------	----------------	------------------

Considerations for Form Completion

W1150150004

Principal Executive Officer

First Name:	Kent	Title:	Executive Director	Telephone:	217-422-6931
Last Name:	Newton				

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample						=	161.0			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.										19 - mg/L		
					Value NODI												
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	222.0			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.										19 - mg/L		
					Value NODI												
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample						=	22.08	=	27.2	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.										19 - mg/L		
					Value NODI												
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	34.51	=	48.19	03 - MGD						99/99 - Continuous	RT - RCOTOT
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							
					Value NODI												

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

SANITARY DISTRICT OF DECATUR

User: keithrsdd
 Name: Keith Richard
 E-Mail: keithr@sddcleanwater.org
 Date/Time: 2023-02-09 09:44 (Time Zone: -06:00)

Report Last Signed By

User: TIMSDD89
 Name: Tim Gorden
 E-Mail: timg@sddcleanwater.org
 Date/Time: 2023-02-10 09:02 (Time Zone: -06:00)