

Monitoring Period: Month: May

Illinois Environmental Protection Agency

No. CSO Discharges Occurred: 4

1021 North Grand Avenue East • P.O. Box 19276 • Springfield • Illinois • 62794-9276 • (217) 782-3397

National Pollutant Discharge Elimination System (NPDES) CSO Discharge Monitoring Report (DMR)

Year: 2023

Name:	Sanitary District of Decatur			Permit Number: IL0028321			
Address:	501 Dipper	Lane					3
City:	Decatur	Decatur		State: IL Zip Code: 62522		22	
Contact Person: Ashley Bailey				Phone Number: (217)422-6931			
Rain Event	Estimated	Estimated	CSO Outfa		that Discharged Est. Discha		Est. Discharge
Start Date	Duration (hours)	Rainfall (inches)	Outfall Number		Outfall Description	Duration (hours)	Volume (MG)
5/7/2023	2	0.37	003		Oakland CSO	2.3	0.35
5/7/2023	2	0.37	007		McKinley CSO	2.4	0.84
5/13/2023	3	0.32	003		Oakland CSO	0.32	0.11
5/13/2023	3	0.32	007		McKinley CSO	2.9	1.01
				Additional Hou	rly Rain Data Available On Red	quest	
					ne information submitted her		

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein and based on my inquiry of those individuals immediately responsible for obtaining the information I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment. Any person who knowingly makes a false, fictitious, or fraudulent material statement, orally or in writing, to the Illinois EPA commits a Class 4 felony. A second or subsequent offense after conviction is a Class 3 felony. (415 ILCS 5/44(h))

Ashley Bailey	Dir. of Compliance & Innovation		
Name of Principal Executive Officer	Title		
Vanlly Bailly	Jun 6, 2023		
Signature /	Date		

IL532-2471 EPA 659 Rev. 11/2016

CSO Discharge Monitoring Report