



Illinois Environmental Protection Agency

1021 North Grand Avenue East • P.O. Box 19276 • Springfield • Illinois • 62794-9276 • (217) 782-3397

National Pollutant Discharge Elimination System (NPDES) CSO Discharge Monitoring Report (DMR)

Monitoring Period: Month: December Year: 2022 No. CSO Discharges Occurred: 5
 Name: Sanitary District of Decatur Permit Number: IL0028321
 Address: 501 Dipper Lane
 City: Decatur State: IL Zip Code: 62522
 Contact Person: Ashley Bailey Phone Number: (217)422-6931

Rain Event Start Date	Estimated Duration (hours)	Estimated Rainfall (inches)	CSO Outfalls that Discharged		Est. Discharge Duration (hours)	Est. Discharge Volume (MG)
			Outfall Number	Outfall Description		
12/14/2022	9	0.87	003	Oakland CSO	5.6	2.23
12/14/2022	9	0.87	007	McKinley CSO	4.5	3.8
12/14/2022	9	0.87	008	7th Ward CSO	4.2	9.04
12/30/2022	10	0.39	003	Oakland CSO	0.17	0.01
12/30/2022	10	0.39	007	**McKinley CSO	0.77	0.85
				**Estimated flow amount due to debris on plate causing false flow reading		
				Additional Hourly Rain Data Available On Request		

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein and based on my inquiry of those individuals immediately responsible for obtaining the information I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment. Any person who knowingly makes a false, fictitious, or fraudulent material statement, orally or in writing, to the Illinois EPA commits a Class 4 felony. A second or subsequent offense after conviction is a Class 3 felony. (415 ILCS 5/44(h))

Ashley Bailey
 Name of Principal Executive Officer

 Signature

Dir. of Compliance & Innovation
 Title
Jan 6, 2023
 Date