

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Facility:		Facility Location:	DECATUR SD MAIN STP 501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	001 External Outfall	Discharge:	001-0 STP OUTFALL

Report Dates & Status			
Monitoring Period:	From 10/01/14 to 10/31/14	DMR Due Date:	11/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
DMF LOAD LIMITS DISPLAYED.

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	8.16									19 - mg/L	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.	>=	6 MINIMUM								19 - mg/L				
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.77				=	8.09			12 - SU	0	02/DA - 2 Days Every Week	GR - GRAB	
					Permit Req.	>=	6 MINIMUM			<=	9 MAXIMUM			12 - SU					
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1405	=	1949	26 - lb/d	=	4	=	7	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	26063 MO AVG	<=	46913 WKLY AVG	26 - lb/d	<=	25 MO AVG	<=	45 WKLY AVG	19 - mg/L				
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	9	--	Sample	=	58	=	79	26 - lb/d	=	0.2	=	0.34	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	1564 MO AVG	<=	3128 DAILY MX	26 - lb/d	<=	1.5 MO AVG	<=	3 DAILY MX	19 - mg/L				
					Value NODI														
X 01067	Nickel, total [as Ni]	1 - Effluent Gross	0	--	Sample	=	5			26 - lb/d	=	0.017			19 - mg/L	1	05/DW - 5 Days Every Week	CP - COMPOS	
					Permit Req.	<=	16 MO AVG			26 - lb/d	<=	.015 MO AVG			19 - mg/L				
					Value NODI														
01092	Zinc, total [as Zn]	1 - Effluent Gross	0	--	Sample	=	5.1	=	8.2	26 - lb/d	=	0.017	=	0.028	19 - mg/L	0	05/DW - 5 Days Every Week	CP - COMPOS	
					Permit Req.	<=	78 MO AVG	<=	434 DAILY MX	26 - lb/d	<=	.075 MO AVG	<=	.416 DAILY MX	19 - mg/L				
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	35.39	=	74.23	03 - MGD						0	99/99 - Continuous		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample							<	0.015	19 - mg/L	0	09/99 - See Permit	GR - GRAB		
					Permit Req.							<=	.05 DAILY MX	19 - mg/L					
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample							=	17	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - GRAB		
					Permit Req.							<=	400 DAILY MX	13 - #/100mL					
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	983	=	1268	26 - lb/d	=	3	=	5	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	20850 MO AVG	<=	41700 WKLY AVG	26 - lb/d	<=	20 MO AVG	<=	40 WKLY AVG	19 - mg/L				
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
01067	Nickel, total [as Ni]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

Name	Type	Size
October_2014_DMR_NON.pdf	pdf	2374325

Report Last Saved By

User: timk@sddcleanwater.org

Date/Time:

2014-11-12 09:07 (Time Zone: -06:00)

Name: Tim Kluge

E-Mail: timk@sddcleanwater.org

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	003 External Outfall	Discharge:	003-0 TREATED CSO-OAKLAND AVENUE
Facility:		Facility Location:	DECATUR SD MAIN STP 501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 10/01/14 to 10/31/14	DMR Due Date:	11/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type					
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1				Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample					=	47			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.										19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.17			12 - SU	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	DL/DS - Daily When Discharging	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	144			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.										19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI													
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	5.84	80 - Mgal/mo						DL/DS - Daily When Discharging	CN - CONTIN		
					Permit Req.											DL/DS - Daily When Discharging	CN - CONTIN	
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 3

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-11-12 09:12 (Time Zone: -06:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	004 External Outfall	Discharge:	004-0 TREATED CSO-SOUTH EDWARD ST
Facility:		Facility:	DECATUR SD MAIN STP
		Facility Location:	501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 10/01/14 to 10/31/14	DMR Due Date:	11/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2				Qualifier 3	Value 3
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample					=	17				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										19 - mg/L			
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.21			=	7.31	12 - SU	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	89				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										19 - mg/L			
					Value NODI													
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	13.1	80 - Mgal/mo							DL/DS - Daily When Discharging	CN - CONTIN	
					Permit Req.													
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 2

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-11-12 09:16 (Time Zone: -06:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	007 External Outfall	Discharge:	007-0 TREATED CSO-MCKINLEY AVENUE
Facility:		Facility:	DECATUR SD MAIN STP
		Facility Location:	501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 10/01/14 to 10/31/14	DMR Due Date:	11/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2				Qualifier 3	Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	25			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.94			=	7.82	12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	94			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	10.3	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN	
					Permit Req.													DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 3

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-11-12 09:20 (Time Zone: -06:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit																			
Permit #: IL0028321	Permittee: DECATUR SD MAIN STP																		
Major: Yes	Permittee Address: 501 DIPPER LANE DECATUR, IL 62522																		
Permitted Feature: 008 External Outfall	Discharge: 008-0 TREATED CSO-SEVENTH WARD																		
Facility: DECATUR SD MAIN STP	Facility Location: 501 DIPPER LANE DECATUR, IL 62522																		
Report Dates & Status																			
Monitoring Period: From 10/01/14 to 10/31/14	DMR Due Date: 11/15/14																		
Status: NetDMR Validated																			
Considerations for Form Completion																			
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF																			
Principal Executive Officer																			
First Name: Monte	Title: Executive Director																		
Last Name: Cherry	Telephone: 217-422-6931																		
No Data Indicator (NODI)																			
Form NODI: --																			
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type							
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--						=	54				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
															19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
00400	pH	1 - Effluent Gross	0	--					=	7.02			=	7.45	12 - SU	DL/DS - Daily When Discharging	GR - GRAB		
									>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB	
00530	Solids, total suspended	1 - Effluent Gross	0	--											19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB		
															19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
82220	Flow, total	1 - Effluent Gross	0	--													DL/DS - Daily When Discharging	CN - CONTIN	
																	0	DL/DS - Daily When Discharging	CN - CONTIN
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Number of days of discharge: 3																			
Attachments																			
No attachments.																			
Report Last Saved By																			
DECATUR SD MAIN STP																			
User: timk@sddcleanwater.org	Date/Time: 2014-11-12 09:23 (Time Zone: -06:00)																		
Name: Tim Kluge																			
E-Mail: timk@sddcleanwater.org																			

DMR Copy of Record

Permit																	
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP							
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522							
Permitted Feature:	A03 External Outfall			Discharge:	A03-0 CSO-OAKLAND AV TRT BYPAS(003A)												
Report Dates & Status																	
Monitoring Period:	From 10/01/14 to 10/31/14			DMR Due Date:	11/15/14				Status:	NetDMR Validated							
Considerations for Form Completion																	
RECEIVING WATER:SANGAMON RIVERGF																	
Principal Executive Officer																	
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931							
Last Name:	Cherry																
No Data Indicator (NODI)																	
Form NODI:	--																
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
74071	Flow	1 - Effluent Gross	0														
				Sample Permit Req. Value NODI				Opt Mon MO TOTAL 4K - #/mo									
								C - No Discharge									
Submission Note																	
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																	
Edit Check Errors																	
No errors.																	
Comments																	
Attachments																	
No attachments.																	
Report Last Saved By																	
DECATUR SD MAIN STP																	
User:	timk@sddcleanwater.org			Date/Time:	2014-11-12 09:24 (Time Zone: -06:00)												
Name:	Tim Kluge																
E-Mail:	timk@sddcleanwater.org																

DMR Copy of Record

<i>Permit</i>																
Permit #: IL0028321		Permittee: DECATUR SD MAIN STP				Facility: DECATUR SD MAIN STP										
Major: Yes		Permittee Address: 501 DIPPER LANE DECATUR, IL 62522				Facility Location: 501 DIPPER LANE DECATUR, IL 62522										
Permitted Feature: A04 External Outfall		Discharge: A04-0 CSO-S EDWARD ST TRT BYPS(004A)														
<i>Report Dates & Status</i>																
Monitoring Period: From 10/01/14 to 10/31/14				DMR Due Date: 11/15/14				Status: NetDMR Validated								
<i>Considerations for Form Completion</i>																
RECEIVING WATER:SANGAMON RIVERGF																
<i>Principal Executive Officer</i>																
First Name: Monte				Title: Executive Director				Telephone: 217-422-6931								
Last Name: Cherry																
<i>No Data Indicator (NODI)</i>																
Form NODI: --																
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
74071	Flow 1 - Effluent Gross	0	--	Sample Permit Req.					Opt Mon MO TOTAL	4K - #/mo						
				Value NODI					C - No Discharge							
<i>Submission Note</i>																
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																
<i>Edit Check Errors</i>																
No errors.																
<i>Comments</i>																
<i>Attachments</i>																
No attachments.																
<i>Report Last Saved By</i>																
DECATUR SD MAIN STP																
User: timk@sddcleanwater.org				Date/Time: 2014-11-12 09:26 (Time Zone: -06:00)												
Name: Tim Kluge																
E-Mail: timk@sddcleanwater.org																

DMR Copy of Record

Permit																			
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP									
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522									
Permitted Feature:	A06 External Outfall			Discharge:	A06-0 CSO-FAIRVIEW PARK														
Report Dates & Status																			
Monitoring Period:	From 10/01/14 to 10/31/14			DMR Due Date:	11/15/14				Status:	NetDMR Validated									
Considerations for Form Completion																			
RECEIVING WATER: UNNAMED TRIB OF SPRING CREEK GF																			
Principal Executive Officer																			
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931									
Last Name:	Cherry																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
74071	Flow	1 - Effluent Gross	0	--															
				Sample															
				Permit Req.				Opt Mon MO TOTAL	4K - #/mo										
				Value NODI				C - No Discharge											
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
No attachments.																			
Report Last Saved By																			
DECATUR SD MAIN STP																			
User:	timk@sddcleanwater.org			Date/Time:	2014-11-12 09:28 (Time Zone: -06:00)														
Name:	Tim Kluge																		
E-Mail:	timk@sddcleanwater.org																		

DMR Copy of Record

Permit																		
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP								
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522								
Permitted Feature:	A07 External Outfall			Discharge:	A07-0 CSO-MCKINLEY AV TR BYPAS(007A)													
Report Dates & Status																		
Monitoring Period:	From 10/01/14 to 10/31/14			DMR Due Date:	11/15/14				Status:	NetDMR Validated								
Considerations for Form Completion																		
RECEIVING WATER:UNNAMED TRIB OF SPRING CREEKGF																		
Principal Executive Officer																		
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931								
Last Name:	Cherry																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74071	Flow	1 - Effluent Gross	0															
				Sample														
				Permit Req.				Opt Mon MO TOTAL	4K - #/mo									
				Value NODI				C - No Discharge										
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org			Date/Time:	2014-11-12 09:28 (Time Zone: -06:00)													
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																	
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP							
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522							
Permitted Feature:	A08 External Outfall			Discharge:	A08-0 CSO-SEVENTH WARD TR BYPS(008A)												
Report Dates & Status																	
Monitoring Period:	From 10/01/14 to 10/31/14			DMR Due Date:	11/15/14				Status:	NetDMR Validated							
Considerations for Form Completion																	
RECEIVING WATER:SANGAMON RIVERGF																	
Principal Executive Officer																	
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931							
Last Name:	Cherry																
No Data Indicator (NODI)																	
Form NODI:	--																
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
74071	Flow	1 - Effluent Gross	0														
				Sample Permit Req.			Opt Mon MO TOTAL	4K - #/mo									
				Value NODI			C - No Discharge										
Submission Note																	
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																	
Edit Check Errors																	
No errors.																	
Comments																	
Attachments																	
No attachments.																	
Report Last Saved By																	
DECATUR SD MAIN STP																	
User:	timk@sddcleanwater.org			Date/Time:	2014-11-12 09:30 (Time Zone: -06:00)												
Name:	Tim Kluge																
E-Mail:	timk@sddcleanwater.org																

DMR Copy of Record

Permit																			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP	Facility:	DECATUR SD MAIN STP														
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522	Facility Location:	501 DIPPER LANE DECATUR, IL 62522														
Permitted Feature:	INF Influent Structure	Discharge:	INF-L INFLUENT REPORTING																
Report Dates & Status																			
Monitoring Period:	From 10/01/14 to 10/31/14	DMR Due Date:	11/15/14	Status:	NetDMR Validated														
Considerations for Form Completion																			
GF																			
Principal Executive Officer																			
First Name:	Monte	Title:	Executive Director	Telephone:	217-422-6931														
Last Name:	Cherry																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample						=	70				19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	107				19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.											19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	32.13	=	70.19	03 - MGD							99/99 - Continuous	RT - RCOTOT	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	RT - RCOTOT	
					Value NODI														
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
No attachments.																			
Report Last Saved By																			
DECATUR SD MAIN STP																			
User:	timk@sddcleanwater.org	Date/Time:	2014-11-12 09:47 (Time Zone: -06:00)																
Name:	Tim Kluge																		
E-Mail:	timk@sddcleanwater.org																		