

DMR Copy of Record

Permit					
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP	Facility:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522	Facility Location:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	001 External Outfall	Discharge:	001-0 STP OUTFALL		

Report Dates & Status					
Monitoring Period:	From 09/01/14 to 09/30/14	DMR Due Date:	10/15/14	Status:	NetDMR Validated

Considerations for Form Completion
DMF LOAD LIMITS DISPLAYED.

Principal Executive Officer					
First Name:	Monte	Title:	Executive Director	Telephone:	217-422-6931
Last Name:	Cherry				

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7.6				=	7.6				19 - mg/L	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.	>=	6 MINIMUM								19 - mg/L				
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.87				=	8.13			12 - SU	0	02/DA - 2 Days Every Week	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM			12 - SU				
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	643	=	793	26 - lb/d	=	2	=	3	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	26063 MO AVG	<=	46913 WKLY AVG	26 - lb/d	<=	25 MO AVG	<=	45 WKLY AVG	19 - mg/L				
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	8	--	Sample	=	82	=	149	26 - lb/d	=	0.32	=	0.48	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	1564 MO AVG	<=	3128 DAILY MX	26 - lb/d	<=	1.5 MO AVG	<=	3 DAILY MX	19 - mg/L				
					Value NODI														
X 01067	Nickel, total [as Ni]	1 - Effluent Gross	0	--	Sample	=	5.3			26 - lb/d	=	0.02			19 - mg/L	1	05/DW - 5 Days Every Week	CP - COMPOS	
					Permit Req.	<=	16 MO AVG			26 - lb/d	<=	.015 MO AVG			19 - mg/L				
					Value NODI														
01092	Zinc, total [as Zn]	1 - Effluent Gross	0	--	Sample	=	3.6	=	7.8	26 - lb/d	=	0.013	=	0.018	19 - mg/L	0	05/DW - 5 Days Every Week	CP - COMPOS	
					Permit Req.	<=	78 MO AVG	<=	434 DAILY MX	26 - lb/d	<=	.075 MO AVG	<=	.416 DAILY MX	19 - mg/L				
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	30.82	=	63.09	03 - MGD						0	99/99 - Continuous		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample							<	0.015	19 - mg/L	0	09/99 - See Permit	GR - GRAB		
					Permit Req.							<=	.05 DAILY MX	19 - mg/L					
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample							=	10	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - GRAB		
					Permit Req.							<=	400 DAILY MX	13 - #/100mL					
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	547	=	691	26 - lb/d	=	2	=	2	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	20850 MO AVG	<=	41700 WKLY AVG	26 - lb/d	<=	20 MO AVG	<=	40 WKLY AVG	19 - mg/L				
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
01067	Nickel, total [as Ni]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

Name	Type	Size
September_2014_DMR_NON.pdf	pdf	185407

Report Last Saved By

User: timk@sddcleanwater.org

Date/Time:

2014-10-13 14:08 (Time Zone: -05:00)

Name: Tim Kluge

E-Mail: timk@sddcleanwater.org

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	003 External Outfall	Discharge:	003-0 TREATED CSO-OAKLAND AVENUE
Facility:		Facility Location:	DECATUR SD MAIN STP 501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 09/01/14 to 09/30/14	DMR Due Date:	10/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	46				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB
					Permit Req.										19 - mg/L			
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.63			12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM			12 - SU
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	141			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.										19 - mg/L			
					Value NODI													
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	7.99	80 - Mgal/mo						DL/DS - Daily When Discharging	CN - CONTIN	
					Permit Req.					Req Mon MO TOTAL	80 - Mgal/mo							
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 3

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-10-13 14:12 (Time Zone: -05:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	004 External Outfall	Discharge:	004-0 TREATED CSO-SOUTH EDWARD ST
Facility:		Facility:	DECATUR SD MAIN STP
		Facility Location:	501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 09/01/14 to 09/30/14	DMR Due Date:	10/15/14
		Status:	NetDMR Validated

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type						
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2				Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	27			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB					
					Permit Req.										Req Mon MO AVG	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.4			=	7.4	12 - SU	DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	130			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB					
					Permit Req.											Req Mon MO AVG	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	1.8	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN				
					Permit Req.															0	DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI																	

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 2

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-10-13 14:26 (Time Zone: -05:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit			
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522
Permitted Feature:	007 External Outfall	Discharge:	007-0 TREATED CSO-MCKINLEY AVENUE
Facility:		Facility:	DECATUR SD MAIN STP
		Facility Location:	501 DIPPER LANE DECATUR, IL 62522

Report Dates & Status			
Monitoring Period:	From 09/01/14 to 09/30/14	DMR Due Date:	10/15/14
Status:	NetDMR Validated		

Considerations for Form Completion
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF

Principal Executive Officer			
First Name:	Monte	Title:	Executive Director
Last Name:	Cherry	Telephone:	217-422-6931

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type						
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2				Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	16			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB					
					Permit Req.										Req Mon MO AVG	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.37			=	7.38	12 - SU	DL/DS - Daily When Discharging	GR - GRAB				
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB			
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	84			19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB					
					Permit Req.											Req Mon MO AVG	19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Value NODI																	
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	10.9	80 - Mgal/mo								DL/DS - Daily When Discharging	CN - CONTIN				
					Permit Req.															0	DL/DS - Daily When Discharging	CN - CONTIN
					Value NODI																	

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Number of days of discharge: 2

Attachments
No attachments.

Report Last Saved By
DECATUR SD MAIN STP

User:	timk@sddcleanwater.org	Date/Time:	2014-10-13 14:29 (Time Zone: -05:00)
Name:	Tim Kluge		
E-Mail:	timk@sddcleanwater.org		

DMR Copy of Record

Permit																		
Permit #: IL0028321	Permittee: DECATUR SD MAIN STP																	
Major: Yes	Permittee Address: 501 DIPPER LANE DECATUR, IL 62522																	
Permitted Feature: 008 External Outfall	Discharge: 008-0 TREATED CSO-SEVENTH WARD																	
Facility: DECATUR SD MAIN STP	Facility Location: 501 DIPPER LANE DECATUR, IL 62522																	
Report Dates & Status																		
Monitoring Period: From 09/01/14 to 09/30/14	DMR Due Date: 10/15/14																	
Status: NetDMR Validated																		
Considerations for Form Completion																		
RECEIVING WATER: SANGAMON RIVER NUMBER OF DAYS OF DISCHARGE:GF																		
Principal Executive Officer																		
First Name: Monte	Title: Executive Director																	
Last Name: Cherry	Telephone: 217-422-6931																	
No Data Indicator (NODI)																		
Form NODI: --																		
Parameter	Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type						
Code	Name			Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--						=	27				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
															19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
00400	pH	1 - Effluent Gross	0	--					=	7.36			=	7.54	12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
									>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	DL/DS - Daily When Discharging	GR - GRAB	
00530	Solids, total suspended	1 - Effluent Gross	0	--						=	107				19 - mg/L	DL/DS - Daily When Discharging	GR - GRAB	
															19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB
82220	Flow, total	1 - Effluent Gross	0	--					=	11.9		80 - Mgal/mo					DL/DS - Daily When Discharging	CN - CONTIN
												Req Mon MO TOTAL 80 - Mgal/mo				0	DL/DS - Daily When Discharging	CN - CONTIN
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Number of days of discharge: 2																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org	Date/Time:	2014-10-13 14:34 (Time Zone: -05:00)															
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																		
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP								
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522								
Permitted Feature:	A03 External Outfall			Discharge:	A03-0 CSO-OAKLAND AV TRT BYPAS(003A)													
Report Dates & Status																		
Monitoring Period:	From 09/01/14 to 09/30/14			DMR Due Date:	10/15/14				Status:	NetDMR Validated								
Considerations for Form Completion																		
RECEIVING WATER:SANGAMON RIVERGF																		
Principal Executive Officer																		
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931								
Last Name:	Cherry																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74071	Flow	1 - Effluent Gross	0	--														
				Sample Permit Req. Value NODI				Opt Mon MO TOTAL 4K - #/mo										
								C - No Discharge										
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Number of days of discharge: 0																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org			Date/Time:	2014-10-13 14:38 (Time Zone: -05:00)													
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																		
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP								
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522								
Permitted Feature:	A04 External Outfall			Discharge:	A04-0 CSO-S EDWARD ST TRT BYPS(004A)													
Report Dates & Status																		
Monitoring Period:	From 09/01/14 to 09/30/14			DMR Due Date:	10/15/14				Status:	NetDMR Validated								
Considerations for Form Completion																		
RECEIVING WATER:SANGAMON RIVERGF																		
Principal Executive Officer																		
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931								
Last Name:	Cherry																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74071	Flow	1 - Effluent Gross	0															
				Sample Permit Req. Value NODI			Opt Mon MO TOTAL	4K - #/mo										
							C - No Discharge											
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Number of days of discharge: 0																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org							Date/Time:	2014-10-13 14:40 (Time Zone: -05:00)									
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																	
Permit #:	IL0028321	Permittee:	DECATUR SD MAIN STP	Facility:	DECATUR SD MAIN STP												
Major:	Yes	Permittee Address:	501 DIPPER LANE DECATUR, IL 62522	Facility Location:	501 DIPPER LANE DECATUR, IL 62522												
Permitted Feature:	A06 External Outfall	Discharge:	A06-0 CSO-FAIRVIEW PARK														
Report Dates & Status																	
Monitoring Period:	From 09/01/14 to 09/30/14	DMR Due Date:	10/15/14	Status:	NetDMR Validated												
Considerations for Form Completion																	
RECEIVING WATER: UNNAMED TRIB OF SPRING CREEK GF																	
Principal Executive Officer																	
First Name:	Monte	Title:	Executive Director	Telephone:	217-422-6931												
Last Name:	Cherry																
No Data Indicator (NODI)																	
Form NODI:	--																
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
74071	Flow 1 - Effluent Gross	0	--	Sample													
				Permit Req.			Opt Mon MO TOTAL	4K - #/mo									
				Value NODI			C - No Discharge										
Submission Note																	
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																	
Edit Check Errors																	
No errors.																	
Comments																	
Number of days of discharge: 0																	
Attachments																	
No attachments.																	
Report Last Saved By																	
DECATUR SD MAIN STP																	
User:	timk@sddcleanwater.org	Date/Time:	2014-10-13 14:42 (Time Zone: -05:00)														
Name:	Tim Kluge																
E-Mail:	timk@sddcleanwater.org																

DMR Copy of Record

Permit																		
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP								
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522								
Permitted Feature:	A07 External Outfall			Discharge:	A07-0 CSO-MCKINLEY AV TR BYPAS(007A)													
Report Dates & Status																		
Monitoring Period:	From 09/01/14 to 09/30/14			DMR Due Date:	10/15/14				Status:	NetDMR Validated								
Considerations for Form Completion																		
RECEIVING WATER:UNNAMED TRIB OF SPRING CREEKGF																		
Principal Executive Officer																		
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931								
Last Name:	Cherry																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74071	Flow	1 - Effluent Gross	0															
				Sample														
				Permit Req.				Opt Mon MO TOTAL	4K - #/mo									
				Value NODI				C - No Discharge										
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Number of days of discharge: 0																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org			Date/Time:	2014-10-13 14:44 (Time Zone: -05:00)													
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																		
Permit #:	IL0028321			Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP								
Major:	Yes			Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522								
Permitted Feature:	A08 External Outfall			Discharge:	A08-0 CSO-SEVENTH WARD TR BYPS(008A)													
Report Dates & Status																		
Monitoring Period:	From 09/01/14 to 09/30/14			DMR Due Date:	10/15/14				Status:	NetDMR Validated								
Considerations for Form Completion																		
RECEIVING WATER:SANGAMON RIVERGF																		
Principal Executive Officer																		
First Name:	Monte			Title:	Executive Director				Telephone:	217-422-6931								
Last Name:	Cherry																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Parameter Code	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
74071	Flow	1 - Effluent Gross	0															
				Sample Permit Req.				Opt Mon MO TOTAL	4K - #/mo									
				Value NODI				C - No Discharge										
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Number of days of discharge: 0																		
Attachments																		
No attachments.																		
Report Last Saved By																		
DECATUR SD MAIN STP																		
User:	timk@sddcleanwater.org							Date/Time:	2014-10-13 14:45 (Time Zone: -05:00)									
Name:	Tim Kluge																	
E-Mail:	timk@sddcleanwater.org																	

DMR Copy of Record

Permit																				
Permit #:	IL0028321				Permittee:	DECATUR SD MAIN STP				Facility:	DECATUR SD MAIN STP									
Major:	Yes				Permittee Address:	501 DIPPER LANE DECATUR, IL 62522				Facility Location:	501 DIPPER LANE DECATUR, IL 62522									
Permitted Feature:	INF Influent Structure				Discharge:	INF-L INFLUENT REPORTING														
Report Dates & Status																				
Monitoring Period:	From 09/01/14 to 09/30/14				DMR Due Date:	10/15/14				Status:	NetDMR Validated									
Considerations for Form Completion																				
GF																				
Principal Executive Officer																				
First Name:	Monte				Title:	Executive Director				Telephone:	217-422-6931									
Last Name:	Cherry																			
No Data Indicator (NODI)																				
Form NODI:	--																			
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample						=	72				19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS		
					Permit Req.								Req Mon MO AVG			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS		
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	132				19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS		
					Permit Req.								Req Mon MO AVG			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS		
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	27.99	=	60.24	03 - MGD							99/99 - Continuous	RT - RCOTOT		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	RT - RCOTOT		
					Value NODI															
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
Attachments																				
No attachments.																				
Report Last Saved By																				
DECATUR SD MAIN STP																				
User:	timk@sddcleanwater.org				Date/Time:	2014-10-13 14:48 (Time Zone: -05:00)														
Name:	Tim Kluge																			
E-Mail:	timk@sddcleanwater.org																			